



TC-16085

QUALITY CONTROL DISTRICT LAB KASARAGOD
FIRST FLOOR, KWA PH DIVISION OFFICE BUILDING, DOOR NO: KMC X/649
KWA COMPOUND, VIDYANAGAR (PO), KASARAGOD, KERALA, INDIA
 Tele phone No : 04994 255791, E-mail - qclabkasaragod@gmail.com

**Test Report**

Test Report No: KWA/QA/R/06/175/MB/16/089

ULR No.: TC-160852600001545F

Report Date 20-06-2026

Customer Name and Address Don Bosco Central School Manjeshwar Manjeshwar Kasaragod 671323 9446265692 HI BFHC Manjeshwaram	1. Date of receipt	18-06-2026
	2. Sampling done by	The Customer(QUA_356351)
	3. Sample Code	82/26/70
	4. Source of sample	Bore Well
	5. Sample condition	Good
	6. Name of sample	Drinking water
	7. Purpose of test	Non Domestic
	8. Sample quantity	250 ml
	9. Test performing dates	From:18/06/2026 To:19/06/2026

Sl No	Test Parameter	Test Method	Aacceptable Limit as per IS 10500:2021	Result
1	Total Coliforms	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detectable in any 100 ml sample	Absent
2	E.coli	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detectable in any 100 ml sample	Absent

Remarks:

- The results reported relate only to the Sample received and tested.
- This test report shall not be reproduced except in full without the written approval of the laboratory.

Sheeba T P
 Reviewed By
 SHEEBA T P
 Bacteriologist

Technical Manager
Quality Control District Lab Kasaragod
Kerala Water Authority
Vidyanagar, Kasaragod - 671123



Manjusha K
 Authorised By
 MANJUSHA K
 Deputy Quality manager

MICROBIOLOGIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
KASARAGOD

* End of Report *

KWA/QC/DL/KSD/MB/R/43	Issue No: 02	Issue Date: 06.05.2022	Rev No: 04	Rev Date: 21.10.2025
-----------------------	--------------	------------------------	------------	-------------------------

The Principal
 Don Bosco Central School
 Manjeshwar Kasaragod
 Kerala - 671 323



TC-16085

QUALITY CONTROL DISTRICT LAB KASARAGOD
FIRST FLOOR, KWA PH DIVISION OFFICE BUILDING, DOOR NO: KMC X/649
KWA COMPOUND, VIDYANAGAR (PO), KASARAGOD, KERALA, INDIA
 Tele phone No : 04994 255791, E-mail - qclabkasaragod@gmail.com

**Test Report**

Test Report No:KWA/QA/R/06/204/J/99/175

ULR No.: TC-160852600001545F

Report Date 20-06-2026

Don Bosco Central School Manjeshwar Manjeshwar Kasaragod 671323 9446265692 HI BFHC Manjeshwaram	1. Date of receipt	18-06-2026
	2. Sampling done by	The Customer(QUA_356351)
	3. Sample Code	82/26/70
	4. Source of sample	Bore Well
	5. Sample condition	GOOD
	6. Name of sample	DRINKING WATER
	7. Purpose of test	Non Domestic
	8. Sample quantity	2 Litre
	9. Test performing dates	From:18/06/2026 To: 19/06/2026


	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012 Amendment No. 4 Nov 2021	Result
1	Colour	HU	IS 3025 (Part 4) : 2021	5	-
2	Odour	--	IS 3025 (Part 5) : 2018	Agreeable	-
3	Taste	--	IS 3025 (Part 8) : 2023	Agreeable	-
4	Turbidity	NTU	IS 3025 (Part 10) : 2023	1	<0.5
5	pH at 25°C	--	IS Part 11 : 2022	6.5 to 8.5	6.5
6	Total Alkalinity (as CaCO ₃)	mg/L	IS 3025 (Part 23) : 2023	200	-
7	Total Dissolved Solids (TDS 180°C	mg/L	IS 3025 (Part 16) : 2023	500	-
8	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 21) : 2023	200	7.26
9	Calcium (as Ca)	mg/L	IS 3025 (Part 40) : 2024	75	-
10	Magnesium (as Mg)	mg/L	IS 3025 (Part 46) : 2023	30	-
11	Chloride (as Cl)	mg/L	IS 3025 (Part 32) : 2025	250	14.67

Note :

1. The results stated above related only to the sample(s) submitted for testing.
2. This test certificate shall not be reproduced except in full without the written approval of the laboratory.
3. Sample will be retained in the laboratory for 5 days.

Reviewed By
 Setlana A V S
 Chemist

Technician
 Quality Control District Lab Kasaragod
 Kerala Water Authority
 Vidyannagar, Kasaragod - 671123



Authorised By
 Haritha A
 Quality Manager

SANITARY CHEMIST
 QUALITY CONTROL DISTRICT LAB
 KERALA WATER AUTHORITY
 KASARAGOD

*** End of Report ***

KWA/QC/DL/KSD/R/17	Issue No: 02	Issue Date: 06.05.2022	Rev No: 005	Rev Date: 17.05.2025
--------------------	--------------	------------------------	-------------	-------------------------

Don Bosco Central School
 Manjeshwar, Kasaragod
 Kerala - 671 323

The Principal
Don Bosco Central School
 Manjeshwar, Kasargod
 Kerala - 671 323



QUALITY CONTROL DISTRICT LAB KASARAGOD
FIRST FLOOR, KWA PH DIVISION OFFICE BUILDING, DOOR NO: KMC X/649
KWA COMPOUND, VIDYANAGAR (PO), KASARAGOD, KERALA, INDIA
Tele phone No : 04994 255791, E-mail - qclabkasaragod@gmail.com

Test Report

Test Report No:KWA/QA/R/06/204/J/99/175

Report Date 20-06-2026

Customer Name and Address	1. Date of receipt	18/06/2026
Don Bosco Central School Manjeshwar Manjeshwar Kasaragod 671323 9446265692 HI BFHC Manjeshwaram	2. Sampling done by	The Customer(QUA_356351)
	3. Sample Code	82/26/70
	4. Source of sample	Bore Well
	5. Sample condition	GOOD
	6. Name of sample	DRINKING WATER
	7. Purpose of test	
	8. Sample quantity	500ml
	9. Test performing dates	
	From:18/06/2026	19-06-2026

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012 Amendment No. 4 Nov 2021	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (Part 14) : 2013 (Reaffirmed 2023)		55.02
2	Acidity	(mg/litre)	IS 3025 (Part 22) : 2024		
3	Sulphate (as So4)	(mg/litre)	IS 3025 (Part 24/Sec 1) : 2022	200	
4	Fluoride (as F)	(mg/litre)	APHA 24 th Edition 4500-F-D SPADNS Method	1	
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) : 2004	1	<0.1
6	Nitrate (as NO ₃)	(mg/litre)	;;	45	<1.0
7	Residual Chlorine	(mg/litre)	IS 3025 (Part 26) : 2021	0.2	


Note :

1. The results stated above related only to the sample(s) submitted for testing.
2. This test certificate shall not be reproduced except in full without the written approval of the laboratory.
3. Sample will be retained in the laboratory for 5 days.


Reviewed By
Setlana AVS
Chemist

Technical Manager
Quality Control District Lab Kasaragod





Authorised By
Haritha A
Quality Manager
SANITARY CHEMIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
KASARAGOD

* End of Report *

KWA/QC/DL/KSD/R/17	Issue No: 03	Issue Date: 25.02.2023	Rev No: 005	Rev Date: 05.04.2025
--------------------	--------------	------------------------	-------------	----------------------


MANAGER
Don Bosco Central School
Manjeshwar, Kasaragod
Kerala - 671 323


The Principal
Don Bosco Central School
Manjeshwar, Kasaragod
Kerala - 671 323